

EC type examination certificate
EG-Baumusterprüfbescheinigung


CE-0085CP0025
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräterichtlinie (2009/142/EG)</i>
Distributor <i>Vertreiber</i>	BOSCH TERMOTEKNIK SANAYI VE TICARET A.S. Organize Sanayi Bölgesi, TR-45030 Manisa
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Combi water heater
Model <i>Modell</i>	Condens 2500 W WBC 24-1...
Countries of Destination <i>Bestimmungsländer</i>	BG, DK, GR, HR, HU, RO, RS, SI, TR
Test Reports <i>Prüfberichte</i>	supplement test: B15/06/1974EU from 30.06.2015 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013)

File Number 15-0344-GEA
Aktenzeichen

7032-04-DE

10.07.2015 Ric C-1/2
 Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



DAkkS
 Deutsche
 Akkreditierungsstelle
 D-ZE-16028-01-01

DVGW CERT GmbH
 Zertifizierungsstelle
 Josef-Wirmer-Str. 1-3
 53123 Bonn
 Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993
 www.dvgw-cert.com
 info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz, IPX4D
Elektrische Daten

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I12H3B/P	20, 28-30 mbar	DK, GR, HR, RO, SI	
I12H3B/P	20, 30 mbar	TR	
I12HS3B/P	25, 28-30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
WBC 14-1 DE 23 BG, HR, RS, SI, DK	nominal heat output: 2,0...14,0 kW heat input (Hi): 2,1...14,4 kW	
WBC 24-1 DE 23 RO, BG, GR, HR, RS, SI, HU	nominal heat output: 3,0...24,1 kW heat input (Hi): 3,1...24,7 kW	
WBC 28-1 DCE 23 RO, BG, GR, HR, RS, SI, HU	nominal heat output: 3,7...24,0 kW heat input (Hi): 3,8...24,7 kW	drinking water: 3,8...28,9 kW
WBC 24-1 DCE 23 TR	nominal heat output: 6,6...23,0 kW heat input (Hi): 6,8...23,4 kW	drinking water: 6,8...30,9 kW

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types B23, B33, C13, C33, C43, C53, C63, C83 and C93: according to installation manual "Condens 2500 W" no. 6 720 842 871

Additional proved countries of destination, appliance categories and supply pressures:

BG, RS: I12H3B/P (20, 28-30 mbar)

In Serbia the conformaty approval will be accepted if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Serbia.